


FIELD INSPECTION REPORT

ITP NO. : No mentioned in ITP
 INSPECTION Gr. : P
 REPORT NO. : FR-ARP-RMA-010
 DATE : 31/JUL/2004

INSPECTION TYPE: GOODS INWARDS INSPECTION		WORK NO : BA-0651	
		ITEM NO : 1	
		LOCATION : C5	
SIGNATURE			
INSPECTION NOTICE NO. : N/A	COMPANY	CONTRACTOR	SUBCONTR.
COMPANY'S INSPECTOR :	21 Aug 2004	31 July 2004	31 JUL/2004
CONTRACTOR'S INSPECTOR : Mr. RASOULI	R. Rasouli	V. Khajepour	V. Khajepour
SUBCONTRACTOR'S INSPECTOR: V.KHAJEPOUR			
DESCRIPTION :	Materials for EXPANTION JOINT		
SUPPLIER :	WANA		
DRAWING NO(S) :	as below		
ACCEPTANCE CRITERIA :			
Q'TY ITEMS RECEIVED :	CONTRACT NO. : SP678-0X-31-011		
Q'TY ITEMS INSPECTED :	SUPPLIERS REF : FOSROC.		
Q'TY ITEMS ACCEPTED :	CERTIFICATION : Technical data of material		
Q'TY ITEMS REJECTED :	COLOUR CODE : N/A		
TO BE COMPLETED BY THE CONTRACTOR. Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS			
			
DISTRIBUTION			
ORIGINAL FILE			
CONSTRUCTION MANAGER			
MATERIAL CONTROLLER			
PLANNING ENGINEER			

LEGEND Q'TY : Quantity N.A. : Not Applicable REF : Reference


RECEIVED

01 AUG 2004 11:56 AM

PPL ASALUVA - PROJECT SP678

FIELD INSPECTION REPORT

ITP NO. :
 INSPECTION Gr. : B
 REPORT NO. : FR-ARP-RMA-025
 DATE : 30/AUG/2004

INSPECTION TYPE: GOODS INWARDS INSPECTION	WORK NO : BA-0651		
	ITEM NO : 1		
	LOCATION : C4b & C5		
SIGNATURE			
INSPECTION NOTICE NO. : N/A	COMPANY	CONTRACTOR	SUBCONTR.
COMPANY'S INSPECTOR :	4 / 29 / 04 / 02 / 09 / 04		31/AUG/2004
CONTRACTOR'S INSPECTOR: Mr. GHASEMI	A. TORABI	<i>[Signature]</i>	V. Khajepour
SUBCONTRACTOR'S INSPECTOR: V. KHAJEPOUR			
DESCRIPTION	: WATERSTOP MATERIAL		
SUPPLIER	: MANA SANAT CO.		
DRAWING NO(S).	: 0000-SPY-2-0000-CV-CI-008-01-D4		
ACCEPTANCE CRITERIA	: ASTM D 638/412/2240		
Q'TY ITEMS RECEIVED :	N/A	CONTRACT NO. :	SP678-0X-31-005,006
Q'TY ITEMS INSPECTED :	N/A	SUPPLIERS REF :	FOSROC.
Q'TY ITEMS ACCEPTED :	N/A	CERTIFICATION :	Technical data of material
Q'TY ITEMS REJECTED :	N/A	COLOUR CODE :	N/A
COMMENTS :			
This material will use as WATER STOP for Fire trap (manhole), sump drum pit....			
TO BE COMPLETED BY THE CONTRACTOR. Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS			
			
DISTRIBUTION			
ORIGINAL FILE CONSTRUCTION MANAGER MATERIAL CONTROLLER PLANNING ENGINEER			

LEGEND Q'TY: Quantity N.A.: Not Applicable REF: Reference

RECEIVED

02 SEP 2004

RECEIVED

FIELD INSPECTION REPORT

ITP NO. : No mentioned in ITP
 INSPECTION Gr. : B
 REPORT NO. : FR-ARP-RMA-0014
 DATE : 03/aug/2004

INSPECTION TYPE: GOODS INWARDS INSPECTION		WORK NO : BA-0651	
		ITEM NO : 1	
		LOCATION : C4B&C5	
		SIGNATURE	
INSPECTION NOTICE NO. : N/A	COMPANY	CONTRACTOR	SUBCONTR.
COMPANY'S INSPECTOR :	14 Aug 04	Aug 10 04	07/AUG/2004
CONTRACTOR'S INSPECTOR : Mr. A.Kamrava	A.TORABI	<i>[Signature]</i>	<i>[Signature]</i>
SUBCONTRACTOR'S INSPECTOR: V. KHAJEPOUR			
DESCRIPTION :	REPAIRING MATERIAL		
SUPPLIER :	MANA SANAT		
DRAWING NO(S) :	REPAIR PROCEDER		
ACCEPTANCE CRITERIA :	According specification		
Q'TY ITEMS RECEIVED : N/A	CONTRACT NO. : SP678-OX-31-005,006,011		
Q'TY ITEMS INSPECTED : N/A	SUPPLIERS REF: FASROC. Brushband		
Q'TY ITEMS ACCEPTED : N/A	CERTIFICATION : Technical data of material.		
Q'TY ITEMS REJECTED :	COLOUR CODE :N/A		
COMMENTS			
<p>This material will use : TO REPAIR ALL CRACK,AIR BULB& HONYCOM(IF ANY).</p> <p>1- Approved only for air bulb and honeycomb 2- For repairing cracks, each material should be approved separately according to crack repair procedure.</p>			
TO BE COMPLETED BY THE CONTRACTOR. Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS			
DISTRIBUTION			
ORIGINAL FILE CONSTRUCTION MANAGER MATERIAL CONTROLLER PLANNING ENGINEER			

RECEIVED


10 AUG 2004

PPL ASALUYA - PROJECT SP678

17.2

FIELD INSPECTION REPORT

ITP NO. :
 INSPECTION Gr. : B
 REPORT NO. : FR-ARP-RP-RMA-026
 DATE : 30/AUG/2004

INSPECTION TYPE: B		WORK NO : BA-0651	
GOODS INWARDS INSPECTION		ITEM NO : N/A	
		LOCATION : C4B&C5	
		SIGNATURE	
INSPECTION NOTICE NO. : N/A	COMPANY	CONTRACTOR	SUBCONTR.
COMPANY'S INSPECTOR :	05/09/04	02/09/04	30/AUG/2004
CONTRACTOR'S INSPECTOR : Mr. GHASEMI	A. TORABI	<i>[Signature]</i>	V. Khajepour
SUBCONTRACTOR'S INSPECTOR: Mr. Khajepour			
DESCRIPTION : <u>Materials of Expanding material (SUPERCAST SWX)</u> .			
SUPPLIER : <u>MANA SANAT</u>			
DRAWING NO(S) : 0000-SPY-2-0000-CV-CI-010-01-D3			
ACCEPTANCE CRITERIA : According to relative. dwg			
QTY ITEMS RECEIVED :	N/A	CONTRACT NO. :	SP678-0X-31-006
QTY ITEMS INSPECTED :	N/A	SUPPLIERS REF :	FOSROC.
QTY ITEMS ACCEPTED :	N/A	CERTIFICATION :	Technical data of material
QTY ITEMS REJECTED :	N/A	COLOUR CODE :	N/A
COMMENTS			
Materials of Expanding material (SUPERCAST SWX) that will use as Watertight seal.			
TO BE COMPLETED BY THE CONTRACTOR, Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS			
			
DISTRIBUTION			
ORIGINAL FILE CONSTRUCTION MANAGER MATERIAL CONTROLLER PLANNING ENGINEER			

LEGEND QTY: Quantity N.A.: Not Applicable REF: Reference

RECEIVED

02 SEP 2004

PPLASALUYA - PROJECT SP678