
 IOEC PPL/IOEC/P PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES	 N.I.O.C Pars Oil & Gas Company
	APPLICATION FOR MATERIAL/VENDOR APPROVAL	
APPLICATION NO: RMA-RGN-017		DATE: 20-Oct-2011
SUBCONTRACTOR: RAHGOSTAR NAFT		DISCIPLINE: Civil
MATERIAL DESCRIPTION: Concure 90		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:		FOSROC
VENDOR'S PRODUCT NAME:		Concure 90
VENDOR'S ADDRESS:		TEHRAN
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD: <u>ASTM C309 & ASHTO M148</u>		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE:20/oct/2011.....	DATE:	DATE:
SIGNATURE:	SIGNATURE:	SIGNATURE:

 IOEG PPL/IOEC/P PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES APPLICATION FOR MATERIAL/VENDOR APPROVAL	 N.I.O.C Pars Oil & Gas Company
APPLICATION NO: RMA-RGN-013 DATE: 12-Oct-2011 SUBCONTRACTOR: RAHGOSTAR NAFT DISCIPLINE: Civil MATERIAL DESCRIPTION: Conbextra GP		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:	FOSROC	
VENDOR'S PRODUCT NAME:	Conbextra GP	
VENDOR'S ADDRESS:	TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD: <u>ASTM C-469-83 & BS 1881 & BS 4551</u>		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 12/oct/2011	DATE:	DATE:
SIGNATURE:	SIGNATURE:	SIGNATURE:





**SOUTH PARS GAS FIELD DEVELOPMENT
PHASE 19 ONSHORE FACILITIES**



**APPLICATION FOR MATERIAL/VENDOR
APPROVAL**

APPLICATION NO: RMA-RGN-019	DATE: 22-Oct-2011
SUBCONTRACTOR: RAHGOSTAR NAFT	DISCIPLINE: Civil
MATERIAL DESCRIPTION: Colpor 200 PF	

APPROVAL FOR: MATERIAL VENDOR

VENDOR'S NAME:	FOSROC
----------------	--------

VENDOR'S PRODUCT NAME:	Colpor 200 PF
------------------------	---------------

VENDOR'S ADDRESS:	TEHRAN
-------------------	--------

ATTACHMENTS: CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS()

REFERENCE SPECIFICATION/STANDARD: ASTM D-1241

COMMENTS:

SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="checked" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input checked="checked" type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 22/oct/2011 SIGNATURE: [Signature]	DATE: [Blank] SIGNATURE: [Signature] 	DATE: [Blank] SIGNATURE: [Signature]



SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES



APPLICATION FOR MATERIAL/VENDOR APPROVAL

N.I.O.C

Pars Oil & Gas Company

APPLICATION NO: RMA-RGN-005 DATE: 24-Aug-2011
 SUBCONTRACTOR: RAHGOSTAR NAFT DISCIPLINE: Civil
 MATERIAL DESCRIPTION: ADMIXTURE SP432MS(FOSROC)

APPROVAL FOR: MATERIAL VENDOR

VENDOR'S NAME:	FOSROC
VENDOR'S PRODUCT NAME:	ADMIXTURE SP432MS
VENDOR'S ADDRESS:	TEHRAN

ATTACHMENTS: CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS()

REFERENCE SPECIFICATION/STANDARD: ASTM C 494

COMMENTS:

SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED

DATE: 24-AUG-2011	DATE: 23/08/2011	DATE:
SIGNATURE:	SIGNATURE:	SIGNATURE:



	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 13 ONSHORE FACILITIES		
	APPLICATION FOR MATERIAL / VENDOR APPROVAL		
APPLICATION NO. :	FN- ARP-999-MA- 0008	DATE :	13-Jul-11
SUBCON/CONTRACTOR :	ABAD RAHAN PARS Co.	DISCIPLINE :	CIVIL
MATERIAL DESCRIPTION :	COATING		
APPROVAL FOR :	<input checked="" type="checkbox"/> MATERIAL	<input checked="" type="checkbox"/> VENDOR	
VENDOR'S NAME:	FARS IRAN Co. (FIOCRO)		
MATERIAL NAME:	NITOPROOF 100		
SUPPLIER'S ADDRESS :	TEHRAN		
ATTACHMENT(S):	<input checked="" type="checkbox"/> CATALOG <input checked="" type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATE <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS(RELATED NOTIFICATION)		
REFERENCE SPECIFICATION / STANDARD:	SPECIFICATION FOR REINFORCED CONCRETE MATERIAL AND CONSTRUCTION (DOC. NO. RP-0013-999-1783-001)		
REMARKS:	INCLUDING TRIAL NOTIFICATION (1 PAGE) + CATALOG (2PAGE) TOTAL 3 PAGES		
SUB-CONTRACTOR	CONTRACTOR	COMPANY	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
DATE:	DATE:	DATE:	
SIGNATURE:	SIGNATURE:	SIGNATURE:	



(Handwritten signature and date)
 9-8-11






OTEC
L3/ DIECI/IOEC
CONSORTIUM



N.I.O.C
Pure Oil & Gas Company

APPLICATION FOR MATERIAL APPROVAL

Project: SP 9-10 Project		Date: 3-May-05
Contract No: POGC-760-81-156		Appl. No.: MA-TSC- 68
Discipline(Subcontractor) : TSC		Pages: Sheets (1 + 2)
Material Description	SEALANT	
References	RP-6340S-999-2010-002	
Specification Ref.	Building Material Spec.and Finishing Schedules	
Vendor's Name	FOSROC	
Vendor's Address	IRAN-TEHRAN	
Vendor's Product	NITOSEAL 125	
Attachments	CATALUGE	
Remarks		

CONFIRMED(QA/QC)		COMPANY(POGC)
Sub Contractor	Contractor	
(Signature)  Name: A-Barzin 3-May-05	 Name: M. M. M. M. M. Date: 5/MAY/05	ACCEPTED  Name: Khorrāmian Date:



**SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 22, 23 & 24**



INSPECTION REPORT FOR MATERIAL/VENDOR APPROVAL

APPLICATION NO. : IN-MMD-2224-MA-0013 DATE : 23-Oct-11

SUBCONTRACTOR : MOHAMMADIAN DISCIPLINE : CIVIL

MATERIAL DESCRIPTION : JOINT FILLER

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC

VENDOR'S PRODUCT NAME : Hydrocell XL

VENDOR'S ADDRESS : TEHRAN


CATALOG DATA SHEET SAMPLE CERTIFICATION

ATTACHMENTS : TEST RESULT DRAWING OTHERS ()

REFERENCE SPECIFICATION/STANDARD : RP-2224-999-1783-001

NOTE Including : CATALOG & DATA SHEET (2Page), This Page -Totally 3 Page

SUBCONTRACTOR	CONTRACTOR	COMPANY
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
Date : 	Date : 24/10/2011	Date : 26/10/2011
Signature : 	Signature : 	Signature : 



**SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 14
ONSHORE FACILITIES**



**APPLICATION FOR
MATERIAL/VENDOR APPROVAL**

APPLICATION NO. : MAT-PA-PAY-BU-00151 DATE : 17-04-2012
 PARTY : PAYANDAN Co./ PAYANDAN Co. DISCIPLINE : Building
 MATERIAL DESCRIPTION : Msstic (Sealing movement joints in Buildings).

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC Co (Farse Iran Co).

VENDOR'S PRODUCT NAME : Thioflex 600* Msstic (Sealing movement joints in Buildings).

VENDOR'S ADDRESS : Khaled Eslamboli St (Vozarae)_No.9_ Tehran.15139_Iran.

ATTACHMENTS : CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS ()

REFERENCE SPECIFICATION/STANDARD : DW-14-999-2001-1004-P REV:0

COMMENTS:

SUBCONTRACTOR	CONTRACTOR		COMPANY
	PARTY	LEADER	
<input checked="" type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVED
<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED
Date: 17/04/2012 Signature: [Signature]	Date: 17/04/2012 Signature: [Signature]	Date: Signature:	Date: Signature: [Signature]

FORM NO. : MAT-002

SubCon Party Leader Company



**SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 14
ONSHORE FACILITIES**



**APPLICATION FOR
MATERIAL/VENDOR APPROVAL**

APPLICATION NO. : MAT-MP-PSP-CV-00006 DATE : 21 MAY 2011
 SUBCONTRACTOR : PANAH SANAAT PART Co. DISCIPLINE : CIVIL
 MATERIAL DESCRIPTION : WATERSTOP

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC CO. (FARS IRAN LTD.)

VENDOR'S PRODUCT NAME : FOSROC: SUPERCASST SW

VENDOR'S ADDRESS : FOSROC CO. (FARS IRAN LTD.)

ATTACHMENTS : CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS ()

REFERENCE SPECIFICATION/STANDARD :

COMMENTS:

SUBCONTRACTOR	CONTRACTOR		COMPANY
	PARTY	LEADER	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: _____ Signature: _____ <input type="checkbox"/> SubCon. <input type="checkbox"/> Party	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: _____ Signature: _____ <input type="checkbox"/> Leader	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT PPROVED Date: _____ Signature: _____ <input type="checkbox"/> Company	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: _____ Signature: _____ <input type="checkbox"/> QC/QA <input type="checkbox"/> WASE TA



**SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 14
ONSHORE FACILITIES**



**APPLICATION FOR
MATERIAL/VENDOR APPROVAL**

APPLICATION NO. : MAT-MP-PSP-CV-00009 DATE : 23 MAY 2011
 SUBCONTRACTOR : PANAH SANAAT PART Co. DISCIPLINE : CIVIL
 MATERIAL DESCRIPTION : WATERSTOP

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC CO. (FARS IRAN LTD.)

VENDOR'S PRODUCT NAME : FOSROC: SUPERCASST PVC

VENDOR'S ADDRESS : FOSROC CO. (FARS IRAN LTD.)

ATTACHMENTS : CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS ()

REFERENCE SPECIFICATION/STANDARD :

COMMENTS:

SUBCONTRACTOR	CONTRACTOR		COMPANY
	PARTY	LEADER	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT PPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
Date: _____ Signature: _____	Date: _____ Signature: _____	Date: _____ Signature: _____	Date: _____ Signature: _____

SubCon. Party Leader Company FORM NO. : MAT-002
 Page 10 of 16



SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 14
ONSHORE FACILITIES



APPLICATION FOR
MATERIAL/VENDOR APPROVAL

APPLICATION NO. : MAT-MP-F/SP-CV-00003 DATE : 21 MAY 2011
 SUBCONTRACTOR : PANAH SANAAT PART Co. DISCIPLINE : CIVIL
 MATERIAL DESCRIPTION : PRIME COATING

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC CO. (FARS IRAN LTD.)

VENDOR'S PRODUCT NAME : FOSROC: NITOPROOF 100

VENDOR'S ADDRESS : FOSROC CO. (FARS IRAN LTD.)

ATTACHMENTS : CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS :

REFERENCE SPECIFICATION/STANDARD :

COMMENTS :

SUBCONTRACTOR	CONTRACTOR		COMPANY
	PARTY	LEADER	
<input checked="" type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVED
<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED
Date: 21 MAY 2011	Date: 21 MAY 2011	Date: 21 MAY 2011	Date: 21 MAY 2011
Signature: [Signature]	Signature: [Signature]	Signature: [Signature]	Signature: [Signature]
<input type="checkbox"/> SubCon	<input type="checkbox"/> Party	<input type="checkbox"/> Leader	<input type="checkbox"/> Company

FORM NO. MAT-001
Page 01 of 01



South Pars Gas Field Development
Phase 14
ONSHORE FACILITIES



FIELD INSPECTION NOTIFICATION

APPLICATION NO: MAT-IP-ETC-CV-01093

DATE: 05-Feb-11

Subcontractor: IPMI / Fara Beton Co.

DISCIPLINE: CIVIL

MATERIAL DESCRIPTION: FOSROK ONPLASR SP40

APPROVAL FOR: MATERIAL METHOD

CONTRACTOR NAME: MANANANAN

FIELD SUPERVISOR NAME: Comptrol SP 1.0

PROJECT ADDRESS: DEIRAN KITALIYENI 353001

ATTACHMENTS: CATALOG PHOTOSET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS

REFERENCE SPECIFICATION STANDARD: RP-14-999-1783-001

Comments:

SUBCONTRACTOR	CONTRACTOR		Company
	PART	LEADER	
<input checked="" type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED
<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> NOT APPROVED
Date:	Date: 17/02/11	Date: 05/02/11	Date:
Signature: M. Mulyedi	Signature: [Signature]	Signature: [Signature]	Signature: [Signature]

Sub Con. Part Leader Company

The field of the field inspection is marked as green if approved by inspection, red if not approved, and yellow if pending. The field of the field inspection is marked as green if approved by inspection, red if not approved, and yellow if pending.



SOUTH PARS GAS FIELD DEVELOPMENT
PHASES 14
ONSHORE FACILITIES

APPLICATION FOR
MATERIAL/VENDOR APPROVAL



APPLICATION NO. : MAT-PA-PAY-BU-00021 DATE : 16-07-2011
 PARTY : PAYANDAN Co./ PAYANDAN Co. DISCIPLINE : Building.
 MATERIAL DESCRIPTION : Grout G2 (For Filling Under Base Plate Of Steel Structures and Equipment).

APPROVAL FOR : MATERIAL VENDOR

VENDOR'S NAME : FOSROC Co. (Farse Iran Co).

VENDOR'S PRODUCT NAME : Grout G2 (Grout Conbextra GP*).

VENDOR'S ADDRESS : Khaled Eslamboli St(Vozarae) No.9_Tehran.15139_Iran.

ATTACHMENTS : CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS ()

REFERENCE SPECIFICATION/STANDARD : RP-14-999-1783-001

COMMENTS:
useable for Trowellable situation

SUBCONTRACTOR	CONTRACTOR		COMPANY
	PARTY	LEADER	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: 15 JUL 2011 Signature: <i>[Signature]</i>	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: 16 JUL 2011 Signature: <i>[Signature]</i>	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED Date: <i>[Signature]</i> Signature: <i>[Signature]</i>	<input checked="" type="checkbox"/> APPROVED with comment <input type="checkbox"/> NOT APPROVED Date: <i>[Signature]</i> Signature: <i>[Signature]</i>

FORM NO. MAT-002
PHASE 14

SubCon. Party Leader Company





APPLICATION FOR MATERIAL APPROVAL

Project: SP 9-10 Project		Date: 10-MAR-05
Contract No: POGC-760-81-156		Appl. No.: MA-TSC-0046
Disciplins(Subcontractor) : TSC		Pages: Sheets (1 + 5)
Material Description	JOINT SEALANT	
References	RP-6340S-999-1783-001	
Specification Ref.	Reinforce concrete material & construction	
Vendor's Name	FOSROC	
Vendor's Address	TEHRAN-IRAN	
Vendor's Product	THIOFLEX 600	
Attachments	Catalogue	
Remarks		

CONFIRMED(QA/QC)		
Sub Contractor -	Contractor	COMPANY(POGC)
(Signature)		
Name: <i>[Signature]</i>	Name: <i>MA-Material</i>	Name: <i>Khorram</i>
Date: 10-MAR-05	Date: 13-MAR-05	Date: 12-03-05





[Handwritten signature]

		SOUTH PARS GAS FIELD DEVELOPMENT PHASES 14 ONSHORE FACILITIES			
		APPLICATION FOR MATERIAL/VENDOR APPROVAL			
APPLICATION NO. : MAT-PA-PAY-CV-00150		DATE : 17-04-2012			
PARTY : PAYANDAN Co./ PAYANDAN Co.		DISCIPLINE : Civil			
MATERIAL DESCRIPTION : Brushbond* (Acrylic Polymer modified protective and decorative coating for concrete).					
APPROVAL FOR : <input checked="" type="checkbox"/> MATERIAL <input type="checkbox"/> VENDOR					
VENDOR'S NAME :		FOSROC Co (Farse Iran Co).			
VENDOR'S PRODUCT NAME :		Brushbond* (Acrylic Polymer modified protective and decorative coating for concrete).			
VENDOR'S ADDRESS :		Khaled Eslamboli St(Vozarae)_No.9_Tehran.15139_Iran.			
ATTACHMENTS : <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS ()					
REFERENCE SPECIFICATION/STANDARD : RP-14-999-1783-001					
COMMENTS:					
SUBCONTRACTOR		CONTRACTOR		COMPANY	
		PARTY LEADER			
<input checked="" type="checkbox"/> APPROVED		<input checked="" type="checkbox"/> APPROVED		<input type="checkbox"/> APPROVED	
<input type="checkbox"/> NOT APPROVED		<input type="checkbox"/> NOT APPROVED		<input type="checkbox"/> NOT APPROVED	
Date: 17/4/2012		Date: 17/4/2012		Date:	
Signature: [Signature]		Signature: [Signature]		Signature: [Signature]	

FORM NO. : MAT-002

SubCon. Party Leader Company

مطلوبه است
 در صورتیکه
 در لیست تامین کننده
 موجود باشد

			
South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2			
Request for Material Approval (RMA)			
Contract No :	CCA /88 / 3174	Document No :	
RMA No :	RMA2-CV-00007	Date :	26 JULY 10
Material Description :	Renderoc TGXtra	<i>H. Sattah</i>	
Vendor Name :	FOSROC Co.		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/> None Approved Vendor <input type="checkbox"/>	Others: (Specify) <input checked="" type="checkbox"/>	<i>This Mat. Category is N/A at Vendor list.</i>
Respective Work Package (Specify) :	Repairing aaAll Concrete Pouring Area		
Drawing No(s) :			
Acceptance Criteria :			
Attachments:	Sample <input type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input checked="" type="checkbox"/> Others: (Specify) <input type="checkbox"/>
Recommendations :			
Contractor:	Company:		
Company Comments : <i>It's accepted</i>			
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name: <i>D. I. ...</i>	Site Manager Name: <i>H. ...</i>		
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>		
COMPANY (PPL) :			
Engineering Department Name: <i>H. ...</i>	Site Manager Name: <i>H. P. Langrudi</i>		
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>		
RMA Approval Status: Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected <input type="checkbox"/>			
<small>Notice: All of the colored field will be filled by Company.</small>			



RECEIVED
 21 JUL 2010
 NO: 0067
 PPL KANGAN - PROJECT



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

Contract No :	CCA / 88 / 3174	Document No :	
RMA No :	RMA2-CV-00022	Date :	9 Aug 2010
Material Description :	Concrete 90		
Vendor Name :	FOSROC Co.		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others (Specify) <input checked="" type="checkbox"/> N/A at Vendor list
Respective Work Package (Specify) :	All Area		
Drawing No(s) :			
Acceptance Criteria :			
Attachments:	Sample <input type="checkbox"/>	Catalogue <input type="checkbox"/>	Certificates <input type="checkbox"/> Others (Specify) <input type="checkbox"/>
Recommendations :			
Contractor:	Company: Accept		
Company Comments :	<p><i>provisionally</i></p> <p>It's accepted. It should be noted that for the purpose of verifying this product has no negative influence on concrete as a trial sample applied by Concrete 90 should be prepared and its 7 days compressive strength should be submitted to Company.</p> <p>H. Vahedi</p>		
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name: <i>A. Nayeri</i> Signature: <i>[Signature]</i>	Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i> DAELIM / SAZEH / KAYSON / I.L.N.D. 30-12 EPC2 DSKI JV		
Engineering Department Name: <i>H. Salehi</i> Signature: <i>[Signature]</i> <i>9-AUG-2010</i>	Site Manager Name: <i>H.P. Langrudi</i> Signature: <i>[Signature]</i> <i>10 Aug 10</i>		
RMA Approval Status: Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected <input type="checkbox"/>			
Notice: All of the colored field will be filled by Company.			



RECEIVED
09 AUG 2010
NO: 00022
PPL KANGARU - PROJECT SP12



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

Contract No :	CCA / 88 / 3174	Document No :	
RMA No :	RMA2-CV-00023	Date :	9.Aug.2010
Material Description :	Dekguard 5		
Vendor Name :	FOSROC Co.		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: <input checked="" type="checkbox"/> N/A at Vendor list <i>S. Hegarakh</i>
Respective Work Package (Specify) :	All Area		
Drawing No(s) :			
Acceptance Criteria :			
Attachments:	Sample <input type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input type="checkbox"/> Others: <input type="checkbox"/> (Specify)
Recommendations :			
Contractor:	Company: <input checked="" type="checkbox"/> Accept		
Company Comments : <i>It's accepted considering following items : ① Two coats of a light grey epoxy paint with a minimum of 125 micrometers per coat should be applied.</i>			
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name: <i>A. Nayan</i> Signature: <i>[Signature]</i>	Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i> Daelim Sazeh Kayson I.I.N.D. SP-12/EPC2/RSK/10		
Engineering Department Name: <i>H. Salehi</i> Signature: <i>[Signature]</i> <i>9-AUG-2010</i>	Site Manager Name: <i>H. P. Langradi</i> Signature: <i>[Signature]</i> <i>10 Aug 10</i>		
RMA Approval Status: Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected <input type="checkbox"/>			

Notice: All of the colored field will be filled by Company.



RECEIVED
09 AUG 2010
0023
S. HANJANI - PROJECT SP12



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

Contract No :	CCA /88 / 3174	Document No :	
RMA No :	RMA2-CV-00008	Date :	20 JULY 10
Material Description :	Nitroproof 100		
Vendor Name :	FOSROC Co.		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: <input checked="" type="checkbox"/> (Specify) <i>This Mat. Category is N/A at Vendor list.</i>
Respective Work Package (Specify) :	All Concrete Pouring Area		
Drawing No(s) :			
Acceptance Criteria :			
Attachments:	Sample <input type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input checked="" type="checkbox"/> Others: <input type="checkbox"/> (Specify)
Recommendations :			
Contractor:	Company:		
Company Comments: <i>It's accepted. f.m.</i>			
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department	Site Manager		
Name: <i>B. Ramani</i>	Name: <i>M. H. ...</i>		
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>		<i>ACCEPT</i>
Engineering Department	Site Manager		
Name: <i>D. V. ...</i>	Name: <i>H. P. Langrudi</i>		
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>		
RMA Approval Status:	Approved <input checked="" type="checkbox"/>	Approved with Comments <input type="checkbox"/>	Rejected <input type="checkbox"/>

Notice: All of the colored fields will be filled by Company.



RECEIVED
21 JUL 2010
NO 0008
KAYSON - PROJECT SP12



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

Contract No : CCA /88 / 3174	Document No :
RMA No : RMA2-CV-00012	Date : 22 JULY 10
Material Description : Complast SP432M	
Vendor Name : Fosroc Co	
Vendor Reference : (To be filled by Company) Approved Vendor <input type="checkbox"/> None Approved Vendor <input type="checkbox"/> Others (Specify) <input checked="" type="checkbox"/> <i>Other Mat. - Complast " info at Vendor kit TWT</i>	
Respective Work Package (Specify) : All Concrete Pouring Area	
Drawing No(s) :	
Acceptance Criteria :	
Attachments: Sample <input type="checkbox"/> Catalogue <input checked="" type="checkbox"/> Certificates <input type="checkbox"/> Others (Specify) <input type="checkbox"/>	
Recommendations :	
Contractor:	Company: <div style="border: 1px solid black; padding: 2px; display: inline-block;"> Accept</div>
Company Comments : <i>It might be accepted based on receiving approved mix designs. [Signature]</i>	
APPROVAL and SIGNATURES	
CONTRACTOR :	
Engineering Department Name: <i>A. Nayem</i> Signature: <i>[Signature]</i>	Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i> <div style="border: 1px solid black; padding: 2px; display: inline-block;">DAEWOO ENGINEERING & CONSTRUCTION CO., LTD. S.P. 12 EPC2 DSKI JV</div>
COMPANY (PPL) :	
Engineering Department Name: <i>[Signature]</i> Signature: <i>[Signature]</i>	Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i>
RMA Approval Status: Approved <input type="checkbox"/> Approved with Comments <input checked="" type="checkbox"/> Rejected <input type="checkbox"/>	
<small>Notice: All of the colored field will be filled by Company.</small>	



cc12



TNDG Consortium
South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No: CCA 88 / 31/5 Document No: Field Procurement
 RMA No: RMA3-CV-09016 Date: 5-Aug-10
 Material Description: Complast SP 432 MS - High Performance Superplasticizing Admixtures
 Vendor Name: Fosroc (Mansana) *H. Sultani*
 Vendor Reference: Approved Vendor Name Approved Vendor Others: *N/A at Vendor List*
 Respective Work Package (Specify): PHASE 12: PLANT AREA (EPC3)

Drawing No(s): N/A
 Acceptance Criteria: According Specification
 Attachments: Sample Catalogue Certificates Others:

Contractor: *Khalid* Company: *Khalid*
 Khosro - Valpour
 Company Comments: *It's accepted.* *Approved*
 Recommendations: **APPROVED**
 07 AUG 2010
 NO: 0018
 PPL KANGAN - PROJECT SP12

Accept



APPROVAL and SIGNATURES

CONTRACTOR:
 Engineering Department: *KH VALIPOUR*
 Name: *KH VALIPOUR* Site Manager: *S. VAHEDIAN*
 Signature: *[Signature]* Name: *S. VAHEDIAN*
 Signature: *[Signature]*

Engineering Department:
 Name: *[Signature]* Site Manager: *[Signature]*
 Signature: *[Signature]* Name: *H.P. Langudi*
 Signature: *[Signature]*
 RMA Approval Status: Approved Approved with Comments Rejected
7 Aug 10



Remark: All of the enclosed will be filled by Company.



INSPECTION REPORT



Date: 22-Aug-08

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (90) (Revived Co) (Mozambique)	
INSPECTION NOTICE NO.: RMA-004-04-01		SIGNATURE	
COMPANY'S INSPECTOR:		CONTRACTOR	
CONTRACTOR'S INSPECTOR: E. Macan		<i>[Signature]</i> 22-Aug-08	
DESCRIPTION: Conplast SP432MS (super plasticizing admixture)			
SUPPLIER: FOSROC Constructive Solutions			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:		CONTRACT NO. 869-004-01793	
QTY ITEMS INSPECTED: N/A		SUPPLIERS REF FOSROC Constructive Solutions	
QTY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
QTY ITEMS REJECTED: N/A			
COMMENT: <i>It is approved, but a new mix design with silver fine and this material shall be submitted</i> <i>[Signature]</i> 22 Aug 08			
TO BE COMPLETED BY THE CONTRACTOR, Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE		RECEIVED	
TECHNICAL OFFICE		25 AUG 2008 0750	
SITE MANAGER		PROJECT 8012	
LEGEND: QTY: Quantity		REF: Reference	
N/A: Not Applicable			



TNDG Consortium
South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3


Request for Material Approval (RMA)

Contract No: CCA 88 / 31/5 Document No: Field Procurement
 RMA No: RMA3-CV-09016 Date: 5-Aug-10
 Material Description: Complast SP 432 MS - High Performance Superplasticizing Admixtures
 Vendor Name: Fosroc (Mansana) *H. Zahedi*
 Vendor Reference: Approved Vendor Name Approved Vendor Others: *N/A at Vendor List*
 Respective Work Package (Specify): PHASE 12: PLANT AREA (EPC3)

Drawing No(s): N/A
 Acceptance Criteria: According Specification
 Attachments: Sample Catalogue Certificates Others:

Contractor: *Kaj* Company: *Kaj*
 Khosro - Valpour
 Company Comments: *It's accepted.* *Approved*
 Recommendations: **APPROVED**
 07 AUG 2010
 NO: 0018
 PPL KANGAN - PROJECT SP12

Accept



APPROVAL and SIGNATURES

CONTRACTOR:
 Engineering Department: *Kaj* Name: KH VALIPOUR
 Signature: *Kaj*
 Site Manager: Name: *S. Vahedian* S - VAHEDIAN
 Signature: *S. Vahedian*

Engineering Department:
 Name: *H.P. Langudi*
 Signature: *H.P. Langudi*
 RMA Approval Status: Approved Approved with Comments Rejected
 7 Aug 10



Remark: All of the enclosed will be filled by Company.



INSPECTION REPORT

016 112142-11

PROJECT TYPE: GOODS INWARDS INSPECTION		LOCATION: EPD/SP12/100	
INSPECTION NOTICE NO.: HMP-NAS/11/02		SIGNATURE	
COMPANY'S INSPECTOR:		CONTRACTOR	SUBCONTRACTOR
CONTRACTOR'S INSPECTOR:			
DESCRIPTION: Insprod 100			
SUPPLIER: PT. ARAC			
DRAWING NO.:			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:	NA	CONTRACT NO.: 00441/10	
QTY ITEMS INSPECTED:	NA	SUPPLIER REFERENCE:	
QTY ITEMS ACCEPTED:	NA	CERTIFICATION: /no/na/	
QTY ITEMS REJECTED:	NA		
COMMENTS:			
TO BE COMPLETED BY THE CONTRACTOR O.C.W. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE:			
TECHNICAL OFFICE			
SIT MANAGER			
LEGEND	QTY : Quantity	NA : Not Applicable	REF : Reference

RECEIVED
 27 FEB 2008
 NO: 0124
 PPL KANGAR - PROJECT SP12






APPLICATION FOR MATERIAL APPROVAL

Project: SP 9-10 Project		Date: 3-May-05
Contract No: POGC-760-81-156		Appl. No.: MA-TSC- 67
Discipline(Subcontractor) : TSC		Pages: Sheets (1 + 2)
Material Description	SEALANT	
References	RP-63405-999-2010-002	
Specification Ref.	Building Material Spec. and Finishing Schedules	
Vendor's Name	FOSROC	
Vendor's Address	IRAN-TEHRAN	
Vendor's Product	NITOSEAL 105	
Attachments	CATALUGE	
Remarks		

CONFIRMED(QA/QC)		
Sub Contractor	Contractor	COMPANY(POGC)
(Signature) Name: A-... Date: 3-May-05	 Name: M-... Date: 5 MAY 05	Khorrámian ACCEPTED Name: Date:

11-AUG-2008 08:08

11-AUG-2008 08:08

 TNDG Consortium South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3		
Request for Material Approval (RMA)		
Contract No :	OCA/89/3175	Document No : Field Procurement
RMA No :	PM/3-EV-0005	Date : 30-Jun-10
Material Description : NITC/PROOF 100 - Concrete Protective Material / Coating		
Vendor Name : Fosroc / Manasani		
Vendor Reference : Approved Vendor <input type="checkbox"/> Non-Approved Vendor <input type="checkbox"/> Others (Specify) <input checked="" type="checkbox"/> <i>This mat category is NIA at AVL-42</i>		
Respective Work Package (Specify) : Iranian Labor Camp (EPC 3-Phase 12) - Plant Area		
Drawing No(s) : SP12-2C3-ST-DW-9D1-005-D1		
Acceptance Criteria : Specification		
Attachments : Sample <input type="checkbox"/> Catalogue <input checked="" type="checkbox"/> Certificate <input type="checkbox"/> Others (Specify) <input type="checkbox"/>		
Recommendations : Contractor: <i>Salipour</i> Company:  RECEIVED 01 JUL 2010 NO: 0004 DE: HANGAN - PROJECT 0910		
Company Comments : <i>According to site material approval procedure, Contractor should submit material and its related documents (i.e data sheet, catalogue etc) atleast from 3 vendors. (materials supplied from approved vendor list not included). It's accepted just for applying in Camps.</i> <i>H. P. Langford</i>		
APPROVAL and SIGNATURES		
CONTRACTOR :		
Engineering Department	TNDG CONSORTIUM	
Name: <i>Salipour</i> KH VALIPOUR	شركت گاما	S: VALIPOUR
Signature: <i>Salipour</i>	GAMMA-CC South Pars Phase 12-EPC3	
COMPANY (PPL) :		
Engineering Department	Project Manager	
Name: <i>Salipour</i>	Name: <i>H. P. Langford</i>	
Signature: <i>Salipour</i>	Signature: <i>H. P. Langford</i>	
RMA Approval Status: Approved <input type="checkbox"/> Approved with Comments <input checked="" type="checkbox"/> Rejected <input type="checkbox"/>		
<small>Notice: All of the colored field will be filled by company</small>		








INSPECTION REPORT

016 112142-11

PROJECT TYPE: GOODS INWARDS INSPECTION		LOCATION: EPD/SP12/100	
INSPECTION NOTICE NO.: HMP-NASR-0102		SIGNATURE	
CONTRACTOR'S INSPECTOR:		CONTRACTOR	SUBCONTRACTOR
CONTRACTOR'S INSPECTOR:			
DESCRIPTION: Insprod 100			
SUPPLIER: PT. ARADIC			
DRAWING NO.:			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:	NA	CONTRACT NO.: HMP/0041/100	
QTY ITEMS INSPECTED:	NA	SUPPLIER REFERENCE:	
QTY ITEMS ACCEPTED:	NA	CERTIFICATION: (none)	
QTY ITEMS REJECTED:	NA		
COMMENTS:			
TO BE COMPLETED BY THE CONTRACTOR O.C.W. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE:			
TECHNICAL OFFICE:			
SIT MANAGER:			
LEGEND	QTY : Quantity	NA : Not Applicable	REF : Reference

RECEIVED
 27 FEB 2008
 NO: 0124
 PPL KANGAR - PROJECT SP12


 TNDG Consortium South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3		
Request for Material Approval (RMA)		
Contract No:	OCA/89/3175	Document No: Field Procurement
RMA No:	PM/O-CV-0005	Date: 30-Jun-10
Material Description: NITC/PROOF 100 - Concrete Protective Material / Coating		
Vendor Name: Fosroc / Mansana		
Vendor Reference: (To be filled by Company) <input type="checkbox"/> Approved Vendor <input type="checkbox"/> Non-Approved Vendor <input checked="" type="checkbox"/> Others (Specify): <i>This mat category is NIA at AVL-42</i>		
Respective Work Package (Specify): Iranian Labor Camp (EPC 3-Phase 12) - Plant Area		
Drawing No(s): SP12-2C3-ST-DW-9D1-005-D1		
Acceptance Criteria: Specification		
Attachments: <input type="checkbox"/> Sample <input checked="" type="checkbox"/> Catalogue <input type="checkbox"/> Certificate <input type="checkbox"/> Others (Specify)		
Recommendations: <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="border: 1px solid black; padding: 5px; transform: rotate(-15deg);"> Accept </div> <div style="border: 1px solid black; padding: 5px; border-radius: 50%; text-align: center;">  </div> <div style="text-align: right;"> RECEIVED 01 JUL 2010 NO. 0004 DE. NANGEN - PROJECT 5010 </div> </div>		
Contractor Comments: <i>According to site material approval procedure, Contractor should submit material and its related documents (i.e. data sheet, catalogue etc) at least from 3 vendors. (materials supplied from approved vendor list not included). It's accepted just for applying in Camps.</i>		
APPROVAL and SIGNATURES		
CONTRACTOR :		
Engineering Department	TNDG CONSORTIUM	
Name: <i>KH VALIPOUR</i>	 GAMMA-CC South Pars Phase 12-EPC3	
Signature: <i>[Signature]</i>		
COMPANY (PPL) :		
Engineering Department		
Name: <i>H. P. Langford</i>	Project Manager	
Signature: <i>[Signature]</i>		
RMA Approval Status: <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected		
<small>Notice: All of the colored field will be filled by company</small>		

South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2 Request for Material Approval (RMA)	
Contract No:	01A/88/1134
Document No:	
RMA No:	01A12 CV 0023
Date:	22 JULY 02
Material Description:	Concrete 9532845
Vendor Name:	Travis Co.
Vendor Reference (To be filled by Company):	<input type="checkbox"/> Approved Vendor <input type="checkbox"/> Non Approved Vendor <input checked="" type="checkbox"/> Others (Specify) <i>This mat category is N/A at Vendor list.</i>
Respective Work Package (Specify):	All Concrete Paving Area
Drawing No(s):	
Acceptance Criteria:	
Attachments:	<input type="checkbox"/> Sample <input type="checkbox"/> Catalogue <input type="checkbox"/> Certification <input type="checkbox"/> Others (Specify)
Recommendations:	
Contractor:	<input checked="" type="checkbox"/> Accept
Company Comments: <i>It might be accepted based on receiving approved mat design.</i>	
APPROVAL and SIGNATURES	
CONTRACTOR:	
Engineering Department Name:	A. Nayeri
Signature:	<i>[Signature]</i>
Site Number:	01A/88/1134
Stamp:	
Engineering Department Name:	H. Valani
Signature:	<i>[Signature]</i>
Stamp:	
RMA Approval Status:	<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Rejected with Comments <input type="checkbox"/> Rejected
<small>Note: All of the comments will be filled by Company</small>	



22 JUL 02
 01A/88/1134
 0023

South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2 Request for Material Approval (RMA)	
Contract No.:	CLA/01/0174
Document No.:	
RMA No.:	RMA7 CV 0005
Date:	10 July 10
Material Description:	Reinforce I/O
Vendor Name:	LOMIE Co
Vendor Reference: (To be filled by Company)	<input type="checkbox"/> Approved Vendor <input type="checkbox"/> Non-Approved Vendor <input checked="" type="checkbox"/> Others (Specify) <i>This Mat. G. G. G. is N/A at Vendor list.</i>
Respective Work Package (Specify):	All Concrete Pouring Area
Drawing No(s):	
Acceptance Criteria:	
Attachments:	<input type="checkbox"/> Sample <input checked="" type="checkbox"/> Catalogue <input checked="" type="checkbox"/> Certificate <input type="checkbox"/> Others (Specify)
Recommendations:	
Contractor:	Company:
Company Comments: <i>It's accepted for</i>	
APPROVAL and SIGNATURES	
CONTRACTOR :	
Engineering Department	Site Manager
Name: <i>KB. K. K. K.</i>	Name:
Signature:	Signature:
Engineering Department	Site Manager
Name: <i>H. V. S.</i>	Name: <i>H. P. Langrath</i>
Signature:	Signature:
RMA Approval Status:	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Rejected with Comments <input type="checkbox"/> Rejected
Note: All of the cells must be filled by Company.	



Contract No: CCA/NR/1174 Document No:
 RMA No: RMA2-CH-00007 Date: 20 JULY 20
 Material Description: Reinforced TGM
 Vendor Name: HOKU Co. *with 9*
 Vendor Reference (To be filled by Company): Approved Vendor None Approved Vendor Others (Specify) *This Mat. Category is N/A at Vendor list*
 Respective Work Package (Specify): Repairing as All Concrete Pouring Area
 Drawing No(s):
 Acceptance Criteria:
 Attachments: Sample Catalogue Certificate Others (Specify)

Recommendations:
 Contractor: Company:
 Company Comments: *It's accepted for* 

APPROVAL and SIGNATURES

CONTRACTOR:
 Engineering Department: Site Manager: 
 Name: *KB Khan* Name: *R. Florke*
 Signature: *[Signature]* Signature: *[Signature]*
Engineering Department (TDC):
 Name: *H. Sater* Name: *R. Langsdorf*
 Signature: *[Signature]* Signature: *[Signature]*
 RMA Approval Status: Approved Approved with Comments Rejected
Note: Also fill the relevant field when filled by Company



RECEIVED
 0007
 2017/07/20



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

Contract No :	CCA /M / 3174	Document No :	
RMA No :	RMA2-CV-0003	Date :	9 Aug 2010
Material Description :	Detguard 5		
Vendor Name :	FOSROC Co.		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others (Specify) <input checked="" type="checkbox"/> N/A at Vendor list J. Elgarnal
Respective Work Package (Specify) :	All Area		
Drawing No(s) :			
Acceptance Criteria :			
Attachments :	Sample <input type="checkbox"/>	Catalogue <input type="checkbox"/>	Certificate <input type="checkbox"/> Others (Specify) <input type="checkbox"/>
Recommendations :			
Contractor :	Company: <input checked="" type="checkbox"/> Accept		
Company Comments :	It's accepted considering following items: @ Two coats of a light gray epoxy paint with a minimum of 125 micrometers per coat to be applied		
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name :	A. Nayer	Site Manager Name :	X SKID
Signature :		Signature :	
COMPANY (PPL) :			
Engineering Department Name :	H. Salehi	Site Manager Name :	H. P. Langradi
Signature :		Signature :	
RMA Approval Status :	Approved <input checked="" type="checkbox"/>	Approved with Comments <input type="checkbox"/>	Rejected <input type="checkbox"/>

Notice: All of the locked field will be filled by Company



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No :	CCA/88 / 3175	Document No :	Field Procurement
RMA No :	RMA3-CV-00063	Date :	2-Mar-11
Material Description :	Non Shrinkage Grout Conboxtra GP (G2)		
Vendor Name :	MANASANAT (FOSROC)		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: <input checked="" type="checkbox"/> <i>MANA at vendor list</i>
Respective Work Package (Specify) :	PLANT / EPC3 <i>M. Farzad</i>		
Drawing No(s) :	SP12-2Y3-ST-DW-160-000-01 Rev D3 and other		
Acceptance Criteria :	According to Drawing & Specification		
Attachments:	Sample <input type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input type="checkbox"/> Others: (Specify) <input type="checkbox"/>
Recommendations :			
Contractor: Dahizadeh <i>[Signature]</i>	Company:		TDC RECEIVED 02 MAR 2011 Doc No: 00198 RPL 12 Onshore Site Office
Company Comments : <i>It's accepted. H. Vatan 03 March 2011</i>			
APPROVAL and SIGNATURES			
Engineering Department Name: VALIPOUR <i>[Signature]</i>	02 03-2011 TNDGI CONSORTIUM Site QA/QC Dep.	CONTRACTOR : Site Manager Name: S-VAHEDIAN <i>[Signature]</i>	
Engineering Department Name: <i>[Signature]</i>	Site Manager Name: <i>[Signature]</i>	RMA Approval Status: Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected <input type="checkbox"/>	

Notice: All of the colored field will be filled by Company.



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No :	CCA /88 / 3175	Document No :	Field Procurement
RMA No :	RMA3-CV-00068	Date :	14-Mar-11
Material Description :	Elastomeric Oil Resistant Sealer Sealant Cold Applied (Polyurethane) for Expansion & Contract Joints		
Vendor Name :	Fosroc - (Mana Sanat) Colpor 200		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: (Specify) <input checked="" type="checkbox"/> <i>Not list vendor</i>
Respective Work Package (Specify) :	Plant (EPC 3) <i>M. Farhad</i>		
Drawing No(s) :	SP12-2YY-CV-DW-999-003-01-02		
Acceptance Criteria :	SPECIFICATION - Refer. Drawing		
Attachments:	Sample <input type="checkbox"/>	Catalogue <input type="checkbox"/>	Certificates <input type="checkbox"/>
Contractor:	Recommendations :		
<i>[Signature]</i> KH-Vallpour	Company:		
Company Comments :	<i>It's accepted.</i>		
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department	Site Manager		
Name: <i>[Signature]</i> K-Vallpour	Name: S-VAHEDIAN		
Signature: <i>[Signature]</i> 	Signature: <i>[Signature]</i>		
Engineering Department	Site Manager		
Name: <i>[Signature]</i> 15 Mar 2011	Name: <i>[Signature]</i> kashisaz		
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i> 15 Mar 11		
RMA Approval Status:	Approved <input checked="" type="checkbox"/>	Approved with Comments <input type="checkbox"/>	Rejected <input type="checkbox"/>

TDC RECEIVED
15 MAR 2011
Reg. No. # 156
PPT-12 Onshore Site Office

Accept
TDC
SP12
15 MAR 2011

Note: All of the colored field will be filled by Company.



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No :	CCA /88 / 3175	Document No :	Field Procurement
RMA No :	RMA3-CV-00069	Date :	24-Jul-11
Material Description :	HIGH PERFORMANCE ,Cross linked , Closed cell , non- absorbent , polyethylene joint filler		
Vendor Name :	FOSROC (Mana Sanat)		
Vendor Reference : (To be filled by Company)	Approved Vendor <input type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: (Specify) <input checked="" type="checkbox"/> <i>M/A AT A/V/L</i>
Respective Work Package (Specify) :	Plant (EPC 3)		
Drawing No(s) :	All Pavings & Expansion joints		
Acceptance Criteria :	According to Drawing		
Attachments:	Sample <input checked="" type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input type="checkbox"/> Others: (Specify) <input type="checkbox"/>
Recommendations :			
Contractor:	Company:		
<i>[Signature]</i> KH- VALIPOUR			
Company Comments :	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <p>TDC RECEIVED</p> <p>24 JUL 2011</p> <p>Rec No: 236</p> <p>PPI 12 Onshore Site Office</p> <p>Accept</p> <p>TDC SPI2 26 JUL 2011</p> </div>		
<i>This material is approved.</i>			
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department	Site Manager		
Name: KH- VALIPOUR	Name: S-VAHEDIAN		
Signatures: <i>[Signature]</i>	Signatures: <i>[Signature]</i>		
<div style="border: 1px solid black; padding: 2px; display: inline-block;">EPC 3 TNDGI CONSORTIUM Site QA/QC Dep.</div>			
Engineering Department	Site Manager		
Name: H. Pasdar	Name: <i>[Signature]</i>		
Signature: <i>[Signature]</i> 25/Jul/2011	Signature: July 26, 2011		
RMA Approval Status:	Approved <input checked="" type="checkbox"/>	Approved with Comments <input type="checkbox"/>	Rejected <input type="checkbox"/>

Notes: All of the colored field will be filled by Company.



TNDGI Consortium
South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No :	CCA /88 / 5175	Document No :	Field Procurement
RMA No :	RMA3-CV-00085	Date :	31-Jul-11
Material Description :	G3 GROUT - Conbextra EP 300 Epoxi Resin Free Flow Grout		
Vendor Name :	FOSROC		
Vendor Reference : (To be filled by Company)	Approved Vendor <input checked="" type="checkbox"/>	None Approved Vendor <input type="checkbox"/>	Others: (Specify) <input type="checkbox"/> <i>H. Pasdar</i>
Respective Work Package (Specify) :	Plant (EPC 3)		
Drawing No(s) :	ALL Vibration Foundation		
Acceptance Criteria :	According to Drawing		
Attachments:	Sample <input type="checkbox"/>	Catalogue <input checked="" type="checkbox"/>	Certificates <input type="checkbox"/> Others: (Specify) <input type="checkbox"/>
Contractor:	<div style="border: 1px solid black; padding: 2px; display: inline-block;"> Approved with Comment 01 AUG 2011 TDC RECEIVE 31 JUL 2011 Reg. No. 00239 P.P. 12 Onshore Site Office </div>		
Company Comments :	<i>According to the attached catalogue the specifications of this material is approved, but Acceptance for apply as G3 grout, is depend on test results that should be done in site.</i> <i>H. Pasdar 31/Jul/2011</i>		
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name: <i>H. Valipour</i> Signature: <i>H. Valipour</i>	<div style="border: 1px solid black; padding: 2px; display: inline-block;"> KH. VALIPOUR EPC 3 TNDGI CONSORTIUM Site & QC Dep. </div>	Site Manager Name: S-VAHEDIAN Signature: <i>S. Vahedian</i>	
Engineering Department Name: H. Pasdar Signature: <i>H. Pasdar 31/Jul/2011</i>		Site Manager Name: <i>Arasapour</i> Signature: August 01, 2011	
RMA Approval Status: Approved <input type="checkbox"/> Approved with Comments <input checked="" type="checkbox"/> Rejected <input type="checkbox"/>			

Notice: All of the colored field will be filled by Company.



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No: CCA /88 / 3175 Document No: Field Procurement

RMA No: RMA3-CV-00088 Date: 17-Aug-11

Material Description: Joint Sealant for All Vertical Joints in Wall of Buildings and Civil Structures (Bund Walls).
(Thioflex 600)

Vendor Name: Fosroc (Mana Sanat)

Vendor Reference: Approved Vender None Approved Vender Others: (Specify) *VIA AT/AVIA*

Respective Work Package (Specify): Plant (EPC 3) *H. Fatemi*

Drawing No(s): SP12-2Y3-CV-MI-108-250-02-D1 & SP12-2Y3-CV-MI-144-002-02-D1

Acceptance Criteria: According to Drawing

Attachments: Sample Catalogue Certificates Others: (Specify)

Recommendations :

Contractor: *[Signature]* Company: **TDC RECEIVED**
KH-VALIPOUR 17 AUG 2011

Company Comments: **Accept**
TDC SPI2 18 AUG 2011

APPROVAL and SIGNATURES

Engineering Department *[Signature]* 17-08-2011 **CONTRACTOR :**






Name: KH-VALIPOUR Site Manager Name: S-YAHEDIAN *[Signature]*
Signature: **EPC 3 TNDGI CONSORTIUM Site QA/QC Dep.** Signature:



Engineering Department Site Manager

Name: *Abbas-Tabrizi* Name: *kashisaz*
Signature: *[Signature]* Signature: *[Signature]* 18 Aug 11

RMA Approval Status: Approved Approved with Comment Rejected




Notice: All of the colored field will be filled by Company.

 		SOUTH PARS GAS FIELD DEVELOPMENT, PHASES 15 & 16 ONSHORE FACILITIES		 N.I.O.C. Pars Oil and Gas Company	
APPLICATION FOR MATERIAL / VENDOR APPROVAL					
APPLICATION NO.:		IN-ARP-999-MA-0001		DATE: 21-Nov-08	
SUBCON. / CONTRACTOR:		ABAD RAHAN PARS CO.		DISCIPLINE: BUILDING	
MATERIAL DESCRIPTION: CONCURE FOR CURING					
APPROVAL FOR: <input checked="" type="checkbox"/> MATERIAL <input type="checkbox"/> VENDOR					
VENDOR'S NAME:		Fars Iran Limited (FOSROC)			
MATERIAL NAME:		CONCURE 90			
SUPPLIER'S ADDRESS:		ASSALUYEH OFFICE			
ATTACHMENT(S): <input checked="" type="checkbox"/> CATALOG <input checked="" type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATE <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS					
REFERENCE SPECIFICATON / STANDARD : SPECIFICATION FOR CONCRETE WORK (DOC. NO. RP-1516-999-1783-001-05)					
REMARKS: 1- INCLUDING CATALOG(2PAGE) + DATA SHEET SPEC (2PAGES) THIS PAGE: TOTALLY 5 PAGES					
SUB-CONTRACTOR		CONTRACTOR		COMPANY	
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> NOT APPROVED		<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
Date: 21 NOV 2008		Date: 21/Nov/08		Date:	
Signature: 		Signature: 		Signature:	

		SOUTH PARS GAS FIELD DEVELOPMENT, PHASES 15 & 16 ONSHORE FACILITIES			
APPLICATION FOR MATERIAL / VENDOR APPROVAL					
APPLICATION NO.:		IN-SNG-999-MA-0011		DATE : 31-Oct-08	
SUBCON. / CONTRACTOR:		SEPANIR CO.		DISCIPLINE: CIVIL	
MATERIAL DESCRIPTION:		COATING MATERIAL <i>for below ground concrete</i>			
APPROVAL FOR:		<input checked="" type="checkbox"/> MATERIAL		<input checked="" type="checkbox"/> VENDOR	
VENDOR'S NAME:		FARS IRAN(FOSROC)			
MATERIAL NAME:		NITOPROOF 100			
SUPPLIER'S ADDRESS:		TEHRAN			
ATTACHMENT(S):		<input type="checkbox"/> CATALOG <input checked="" type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATE <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS			
REFERENCE SPECIFICATION / STANDARD : SPECIFICATION FOR REINFORCED CONCRETE MATERIAL AND CONSTRUCTION (DOC. NO. RP-1516-999-1783-001)					
REMARKS: 1- INCLUDING DATA SHEET: TOTALLY 3 PAGES					
SUB-CONTRACTOR		CONTRACTOR		COMPANY	
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
Date:		Date: <i>31/oct/08</i>		Date: <i>01-Nov-2008</i>	
Signature: N/A		Signature: <i>M.R. Shama</i>		Signature: <i>M. Beyzani manesh</i>	



The proposed material is approved only for use in below ground concrete protection.

 		SOUTH PARS GAS FIELD DEVELOPMENT, PHASES 15 & 16 ONSHORE FACILITIES		 N.I.O.C. Pars Oil and Gas Company	
APPLICATION FOR MATERIAL / VENDOR APPROVAL					
APPLICATION NO.:		IN-SNC-999-MA-0007	29-Oct-08		
SUBCON. / CONTRACTOR:		SEPANIR CO.	CIVIL		
MATERIAL DESCRIPTION:		CONCRETE ADMIXTURE			
APPROVAL FOR:		<input checked="" type="checkbox"/> MATERIAL		<input checked="" type="checkbox"/> VENDOR	
VENDOR'S NAME:		FARS IRAN CO			
MATERIAL NAME:		ADMIXTURE(SUPERPLASTISIZER)- CONPLAST SP430			
SUPPLIER'S ADDRESS:		TEHRAN, BOKHAREST ST., ARGENTINA SQ.			
ATTACHMENT(S):		<input type="checkbox"/> CATALOG <input checked="" type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATE <input checked="" type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS			
REFERENCE SPECIFICATON / STANDARD : SPECIFICATION FOR REINFORCED CONCRETE MATERIAL AND CONSTRUCTION (DOC. NO. RP-1516-999-1783-001)					
REMARKS: 1- INCLUDING TEST RESULTS (2 PAGES) + RELATED INSPECTION NOTIFICATION & REPORT(10 PAGES)- + DATA SHEET(2 PAGES): TOTALLY 15 PAGES					
SUB-CONTRACTOR		CONTRACTOR		COMPANY	
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
Date:		Date: 29/oct/08		Date: 29-oct-08	
Signature: N/A		Signature: <i>M.R. Shamsi</i>		Signature: <i>A. Hamidi</i>	





South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

contract No : CCA/88/3174 Document No :

RMA NO: RMA2-CV-00168 Date : 27-Jul-11

Material Description : Supercast PVC (PVC Water stop)

Vendor Name : Fosroc

Vendor Reference : (To be filled by Company) Approved Vendor Nbn Approved Vendor Others: (Specify) *M. Sallal 9*

Respective Work Package (Specify) : Unit 125 (Sea water Intake basin "125-X-101" general plan "3/3")

Drawing No(s) : SP12-2Y2-CV-DW-125-503-03-D4 SP12-2Y2-CV-DW-125-503-10-D4 SP12-2Y2-CV-DW-125-503-11-D4
SP12-2Y2-CV-DW-125-503-12-D3 SP12-2Y2-CV-DW-125-503-13-D3 SP12-2Y2-CV-DW-125-503-14-D3

Acceptance Criteria :

Attachments: Sample Catalogue Certificates Others: (Specify) Data sheet

Recommendations :

Contractor: *Accept*
TDC RECEIVED
27 JUL 2011
Reg.No: 00373
PPL 12 Onshore Site Office

Company Comments :
The submitted water stop is accepted and should be used in all construction joints positions

APPROVAL and SIGNATURES

CONTRACTOR :

<p>Engineering Department Name: <i>A. Rahmati</i> FEM: Signature: <i>27-July-2011</i></p>	<p>Site Manager Name: Signature: <i>M. SAZEN 27.07.2011</i></p>
---	---

COMPANY (PPL) :

<p>Engineering Department Name: <i>A. Mohammad Pour</i> Signature: <i>28 July 2011</i></p>	<p>Site Manager Name: <i>A. Mohammad Pour</i> Signature: <i>28 July 2011</i></p>
--	--


RMA Approval Status: Approved Approved with Comments Rejected

Notice: All of the colored field will be filled by Company.



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC2

Request for Material Approval (RMA)

contract No : CCA/88/3174		Document No :	
RMA NO: RMA2-CV-00224		Date : 25-Dec-11	
Material Description : HYDROCELL XL (JOINT FILLER)			
Vendor Name : Mana Sanat Co. (Fosroc)			
Vendor Reference : (To be filled by Company) Approved Vendor <input type="checkbox"/> None Approved Vendor <input type="checkbox"/> Others: (Specify) <input checked="" type="checkbox"/> <i>MAA02</i> <i>AVI-CV-SP-12</i>			
Respective Work Package (Specify) : WP-02 (only for filler, not sealant)			
Drawing No(s) : SP12-2YY-CV-DW-999-003-01-D2			
Acceptance Criteria :			
Attachments: Sample <input checked="" type="checkbox"/> Catalogue <input checked="" type="checkbox"/> Certificates <input type="checkbox"/> Others: (Specify) <input checked="" type="checkbox"/> <i>Standars Certification</i> <i>Old RMA2-CV-00215</i>			
Recommendations :			
Contractor:		Company:	
			
Company Comments : <i>It's accepted.</i>			
APPROVAL and SIGNATURES			
CONTRACTOR :			
Engineering Department Name: <i>P. Yousefi</i> Signature: <i>[Signature]</i> <i>25-Dec-2011</i>		Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i> <i>25-12-2011</i>	
COMPANY (PPL) :			
Engineering Department Name: <i>[Signature]</i> Signature: <i>[Signature]</i> <i>28 Dec 2011</i>		Site Manager Name: <i>[Signature]</i> Signature: <i>[Signature]</i> <i>28/Dec/2011</i>	
RMA Approval Status: Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected <input type="checkbox"/>			
Notice: All of the colored field will be filled by Company.			



INSPECTION REPORT

Date: 25-Aug-06

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (SD) Navros Co. (storage)	
INSPECTION NOTICE NO.: RMA-CV-011 R1		INSPECTOR'S SIGNATURE	
COMPANY'S INSPECTOR:		COMPANY:	CONTRACTOR:
CONTRACTOR'S INSPECTOR: E. Nazer			
DESCRIPTION: Loctite SBQ For Anchor Bolt Repairing (Mix and place polyester resin anchoring grouts)			
SUPPLIER: FOSROC Constructive Solutions			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:		CONTRACT NO.: 861 CCA-01793	
QTY ITEMS INSPECTED: N/A		SUPPLIERS REF FOSROC Constructive Solutions	
QTY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
QTY ITEMS REJECTED: N/A			
COMMENT: <i>The sample should be submitted.</i> <i>J. H. H.</i> <i>25 Aug 06</i>			
TO BE COMPLETED BY THE CONTRACTOR Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE			
TECHNICAL OFFICE			
SITE MANAGER			
LEGEND	QTY: Quantity	N/A: Not Applicable	REF: Reference



INSPECTION REPORT

Date: 20-4-20

INSPECTION TYPE: GOODS INWARDS INSPECTION	LOCATION: Legeur Camp (BD)Navrod Co (storage)
--	---

INSPECTION NOTICE NO: RMA-DV-012 R1	COMPANY:	CONTRACTOR:
-------------------------------------	----------	-------------

COMPANY'S INSPECTOR:

CONTRACTOR'S INSPECTOR: E. Nassif

DESCRIPTION: **Concrete CR (Fos)** : 02 (General purpose for other demarcation grid)

SUPPLIER: **FOSROC Constructive Solutions**

DRAWING NO(S): N/A

ACCEPTANCE CRITERIA: According To Specification

QTY ITEMS RECEIVED:	CONTRACT NO: 821004-01793
---------------------	---------------------------

QTY ITEMS INSPECTED: N/A	SUPPLIER REF: FOSROC Constructive Solutions
--------------------------	---

QTY ITEMS ACCEPTED: N/A	CERTIFICATION: Attachment
-------------------------	---------------------------

QTY ITEMS REJECTED: N/A	
-------------------------	--

COMMENT:

The samples should be submitted
for analysis

TO BE COMPLETED BY THE CONTRACTOR OR TO FOLLOW THIS LINE

RECOMMENDATIONS:

DISTRIBUTION

ORIGINAL FILE

TECHNICAL OFFICE

LEGEND: QTY Quantity

N/A Not Applicable

REF: Reference

RECEIVED
 20-4-20 07:00
 0012



INSPECTION REPORT



Date: 20-Aug-06

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (SD)Navrod Co.(storage)	
INSPECTION NOTICE NO.: RMA-CV-016 R1		SIGNATURE	
COMPANY'S INSPECTOR:		COMPANY	CONTRACTOR
CONTRACTOR'S INSPECTOR: E.Nazer		20-Aug-06	
DESCRIPTION: Silica fume admixture			
SUPPLIER: FOSPOC Constructive Solutions (Mena sanati)			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification SP12-2Y-CV-SF-993-010			
Q'TY ITEMS RECEIVED:		CONTRACT NO: 861CCA-01783	
Q'TY ITEMS INSPECTED: N/A		SUPPLIERS REF: FOSPOC Constructive Solutions	
Q'TY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
Q'TY ITEMS REJECTED: N/A			
COMMENT: <i>The sample should be submitted for testing as per spec</i>			
TO BE COMPLETED BY THE CONTRACTOR, O.C.M. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION		RECEIVED	
ORIGINAL FILE		20 AUG 2006 0950	
TECHNICAL OFFICE		0910	
SITE MANAGER		CONTRACTOR'S SIGNATURE	
LEGEND	QTY : Quantity	N.A. : Not Applicable	REF : Reference



INSPECTION REPORT

Date: 22-4-2025

INSPECTION TYPE: GOODS INWARDS INSPECTION	LOCATION: Lakshmi Dams, Solapur, Dist. Solapur
--	--

INSPECTION NOTICE NO.: PWA-0402/2025	SIGNATURE
--------------------------------------	-----------

COMPANY'S INSPECTOR:	CONTRACT NO.	CONTRACTOR
----------------------	--------------	------------

CONTRACTOR'S INSPECTOR: E. N. S. D. S.		
--	--	--

DESCRIPTION: **Concrete Spacing** - Insulating admixture.

SUPPLIER: **ROBROD Constructive Sol.**

DRAWING NO(S): N/A

ACCEPTANCE CRITERIA: According To Specification

QTY ITEMS RECEIVED:	CONTRACT NO: SBY004-01785
---------------------	---------------------------

QTY ITEMS INSPECTED: N/A	SUPPLIER'S REF: ROBROD Constructive Sol.
--------------------------	--

QTY ITEMS ACCEPTED: N/A	CERTIFICATION: Attachment
-------------------------	---------------------------

QTY ITEMS REJECTED: N/A	
-------------------------	--

COMMENT:

It is approved, that the material is with better quality and this material is for the substructure.

E. N. S. D. S.

TO BE COMPLETED BY THE CONTRACTOR QTY BELOW THIS LINE

RECOMMENDATIONS:

DISTRIBUTION

ORIGINAL FILE

TECHNICAL OFFICE

SITE MANAGER

LEGEND	QTY: Quantity	N/A: Not Applicable	REF: Refer to
--------	---------------	---------------------	---------------



OTEC
LG/ OIEC/ IOEC
CONSORTIUM





APPLICATION FOR MATERIAL APPROVAL





Project: SP 9-10 Project		Date: 24-DEC-04
Contract No: POGC-760-81-156		Appl. No.: MA-TSC-0029
Discipline(Subcontractor) :		Pages: Sheets (1 + 2)
Material Description	EXPANSION JOINT MATERIAL FOR BUILDING	
References	GENERAL DETAILS	
Specification Ref.	STANDARD DRAWINGS	
Vendor's Name	FOSROC	
Vendor's Address	TEHRAN - IRAN	
Vendor's Product	EXPANCELL	
Attachments	CATALOGUE & SAMPLE	
Remarks		






CONFIRMED(QA/QC)		
Sub Contractor	Contractor	COMPANY(POGC)
(Signature) Name: A. Barzin Date: 24-DEC-04	 Name: H. Davudsh Date: 24, Dec	 Name: Date: 30-Dec-2004.

Handwritten notes and signatures at the bottom left of the page.






		SOUTH PARS GAS FIELD DEVELOPMENT, PHASES 15 & 16 ONSHORE FACILITIES			
APPLICATION FOR MATERIAL / VENDOR APPROVAL					
APPLICATION NO.:		IN-SNC-999-MA-0012		DATE : 31-Oct-08	
SUBCON. / CONTRACTOR:		SEPANIR CO.		DISCIPLINE: CIVIL	
MATERIAL DESCRIPTION:		REPAIR MATERIAL			
APPROVAL FOR:		<input checked="" type="checkbox"/> MATERIAL		<input checked="" type="checkbox"/> VENDOR	
VENDOR'S NAME:		FARS IRAN(FOSROC)			
MATERIAL NAME:		RENDEROC TG			
SUPPLIER'S ADDRESS:		TEHRAN			
ATTACHMENT(S):		<input type="checkbox"/> CATALOG <input checked="" type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATE <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS			
REFERENCE SPECIFICATION / STANDARD : SPECIFICATION FOR REINFORCED CONCRETE MATERIAL AND CONSTRUCTION (DOC. NO. RP-1516-999-1783-001)					
REMARKS: 1- INCLUDING DATA SHEET: TOTALLY 3 PAGES <i>Accepted if strength test result satisfied specification. According to Report No. GST-TMT-SNC-0001, strength test results are accepted. 18 Dec 2008.</i>					
SUB-CONTRACTOR		CONTRACTOR		COMPANY	
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED		<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
Date:		Date: 31/oct/08		Date: 2/Nov/08	
Signature: N/A		Signature: <i>M. R. Shams</i>		Signature: <i>H. J. J.</i>	





 IOEC PPL/IOEC/PI		SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES	 N.I.O.C Nas Oil & Gas Company
APPLICATION NO: RMA-RGN-016		DATE: 18-Oct-2011	
SUBCONTRACTOR: RAHGOSTAR NAFT		DISCIPLINE: Civil	
MATERIAL DESCRIPTION: Thioflex 600			
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR			
VENDOR'S NAME:		FOSROC	
VENDOR'S PRODUCT NAME:		Thioflex 600	
VENDOR'S ADDRESS:		TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()			
REFERENCE SPECIFICATON/STANDARD: ASTM C 920-87			
COMMENTS:			
SUBCONTRACTOR	CONTRACTOR	COMPANY	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
DATE: 18/oct/2011	DATE:	DATE:	
SIGNATURE:	SIGNATURE: 	SIGNATURE: 	

 IOEC PPL/IOEC/PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES APPLICATION FOR MATERIAL/VENDOR APPROVAL	 N.I.O.C Pars Oil & Gas Company
APPLICATION NO: RMA-RGN-014 DATE: 13/24/2011 SUBCONTRACTOR: RAHGOSTAR NAFT DISCIPLINE: Civil MATERIAL DESCRIPTION: Super Cast PVC		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:	FOSROC	
VENDOR'S PRODUCT NAME:	Super Cast PVC	
VENDOR'S ADDRESS:	TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD:		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 13/oct/2011	DATE:	DATE:
SIGNATURE: 	SIGNATURE: 	SIGNATURE: 



 IOEC PPL/IOEC/PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES APPLICATION FOR MATERIAL/VENDOR APPROVAL	 N.I.O.C Pars Oil & Gas Company
APPLICATION NO: RMA-RGN-012		DATE: 09-Oct-2011
SUBCONTRACTOR: RAHGOSTAR NAFT		DISCIPLINE: Civil
MATERIAL DESCRIPTION: Renderoc TGXtra		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="checked" type="checkbox"/> VENDOR		
VENDOR'S NAME:		FOSROC
VENDOR'S PRODUCT NAME:		RENDEROC TGXTRA
VENDOR'S ADDRESS:		TEHRAN
ATTACHMENTS: <input checked="checked" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION		
<input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD: ASTM C157-93		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="checked" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 09/oct/2011	DATE:	DATE:
SIGNATURE: 	SIGNATURE:  <i>Phase 19 Quality Control Dept</i>	SIGNATURE: 

 PPL/IOEC/PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES		 N.I.O.C Pars Oil & Gas Company
	APPLICATION FOR MATERIAL/VENDOR APPROVAL		
APPLICATION NO: RMA-RGN-022		DATE: 24-Oct-2011	
SUBCONTRACTOR: RAHGOSTAR NAFT		DISCIPLINE: Civil	
MATERIAL DESCRIPTION: Reebol			
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR			
VENDOR'S NAME:		FOSROC	
VENDOR'S PRODUCT NAME:		Reebol	
VENDOR'S ADDRESS:		TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()			
REFERENCE SPECIFICATON/STANDARD:			
COMMENTS:			
SUBCONTRACTOR	CONTRACTOR	COMPANY	
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	
DATE:24/oct/2011.....	DATE:	DATE:	
SIGNATURE:	SIGNATURE:	SIGNATURE:	






**SOUTH PARS GAS FIELD DEVELOPMENT
PHASE 19 ONSHORE FACILITIES**



**APPLICATION FOR MATERIAL/VENDOR
APPROVAL**

APPLICATION NO: **RMA-RGN-020** DATE: 23-Oct-2011
SUBCONTRACTOR: **RAHGOSTAR NAFT** DISCIPLINE: Civil
MATERIAL DESCRIPTION: **Nitrobond AR**

APPROVAL FOR: MATERIAL VENDOR








VENDOR'S NAME: FOSROC
VENDOR'S PRODUCT NAME: Nitrobond AR
VENDOR'S ADDRESS: TEHRAN



ATTACHMENTS: CATALOG DATA SHEET SAMPLE CERTIFICATION
 TEST RESULT DRAWING OTHERS()


REFERENCE SPECIFICATON/STANDARD: BS 6920



COMMENTS:

SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 23/oct/2011	DATE:	DATE:
SIGNATURE:	SIGNATURE:	SIGNATURE:

 SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES		 N.I.O.C <small>Natural Gas Company</small>
APPLICATION FOR MATERIAL/VENDOR APPROVAL		
APPLICATION NO: RMA-RGN-021		DATE: 24-Oct-2011
SUBCONTRACTOR: RAHGOSTAR NAFT		DISCIPLINE: Civil
MATERIAL DESCRIPTION: Lok fix		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:	FOSROC	
VENDOR'S PRODUCT NAME:	Lok fix	
VENDOR'S ADDRESS:	TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATION/STANDARD: <u>BS 8110</u>		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 24/oct/2011	DATE: 	DATE: 
SIGNATURE: 	SIGNATURE: 	SIGNATURE: 

 <p>IOEC PPL/IOEC/P PI</p>	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES APPLICATION FOR MATERIAL/VENDOR APPROVAL	 <p>N.I.O.C Nars Oil & Gas Company</p>
APPLICATION NO: RMA-RGN-015 DATE: 17-Oct-2011 SUBCONTRACTOR: RAHGOSTAR NAFT DISCIPLINE: Civil MATERIAL DESCRIPTION: Hydrocell XL		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:	FOSROC	
VENDOR'S PRODUCT NAME:	Hydrocell XL	
VENDOR'S ADDRESS:	TEHRAN	
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD: <u>ASTM D3575</u>		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 17/oct/2011	DATE: _____	DATE: _____
SIGNATURE: _____	SIGNATURE: _____	SIGNATURE: _____



 IOEC PPL/IOEC/P PI	SOUTH PARS GAS FIELD DEVELOPMENT PHASE 19 ONSHORE FACILITIES	 N.I.O.C <small>Nars Oil & Gas Company</small>
APPLICATION FOR MATERIAL/VENDOR APPROVAL		
APPLICATION NO: RMA-RGN-018 DATE: 21-Oct-2011 SUBCONTRACTOR: RAHGOSTAR NAFT DISCIPLINE: Civil MATERIAL DESCRIPTION: Dek guard S		
APPROVAL FOR: <input type="checkbox"/> MATERIAL <input checked="" type="checkbox"/> VENDOR		
VENDOR'S NAME:		FOSROC
VENDOR'S PRODUCT NAME:		Dek guard S
VENDOR'S ADDRESS:		TEHRAN
ATTACHMENTS: <input checked="" type="checkbox"/> CATALOG <input type="checkbox"/> DATA SHEET <input type="checkbox"/> SAMPLE <input type="checkbox"/> CERTIFICATION <input type="checkbox"/> TEST RESULT <input type="checkbox"/> DRAWING <input type="checkbox"/> OTHERS()		
REFERENCE SPECIFICATON/STANDARD: <u>ASTM C-672</u>		
COMMENTS:		
SUBCONTRACTOR	CONTRACTOR	COMPANY
<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED	<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED
DATE: 21/Oct/2011 SIGNATURE:	DATE: SIGNATURE:	DATE: SIGNATURE: