



PARS PETROCHEMICAL CO  
SITE ASALUYE

REF:-PPC(S)/NST(S)/L/ 140

Date: 06.01.2003

M/s Navrood Steam Co JV  
C2 Cracker Project  
Assaluyeh.

Attn: Mr. Sh. Tabibzadeh, Project Manager

Sub: Construction of Ethane Cracking Plant -  
**NON-SHRINK GROUTING MATERIAL**

Dear Sir,

This has reference to your letter no. NST/PPC-L-193 dated 05.01.03, proposing use of non-shrink cement based grout of Fosroc make (brand name **Conbextra GP**).

We have reviewed the technical data of M/s Fosroc and found the product acceptable for grouting of Structural steel work.

Thanking you,

Very truly yours,

(A. Jahromi)  
Construction Manager

Copy:  
Mr. M. Maddahi, SM/PPC  
Mr. T.K.Sen, CM, MC

I NST JV	
Ni.	1240
De.	06/01/03
RE.	IVED:06/01/03

NST JV (Site)	
RC'D Date:	
TD:	
To:	1 2 Note
PM	/
SM	/
AM1	/
AM2	/
AM3	/
AM4	/
PCM	/
TOM	/
OC/OA	/
MM	/
HSE	/
Pre-Com	/
FAM	/
SC	/
NAV SI	/
ST	/
TE	/
FI	/
CH	/
Distributed by:	

100% Control, F. Trial, P. Permit, C. Cover  
21 Dec 2002, B. Reply, S1. Implementation



# INSPECTION REPORT



Date: 22-Aug-08

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (90) (Revved Co) (Maha)	
INSPECTION NOTICE NO.: RM-024-ART		SIGNATURE	
COMPANY'S INSPECTOR:		CONTRACTOR	
CONTRACTOR'S INSPECTOR: E. Hajar		22-Aug-08	
DESCRIPTION: Conplast SP432MS (super plasticizing admixture)			
SUPPLIER: FOSROC Constructive Solutions			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:		CONTRACT NO. 861-DA-01793	
QTY ITEMS INSPECTED: N/A		SUPPLIER REF FOSROC Constructive Solutions	
QTY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
QTY ITEMS REJECTED: N/A			
COMMENT: <i>It is approved, but a new mix design with silver fine and this material shall be submitted</i> <i>Hajar</i> <i>22 Aug 08</i>			
TO BE COMPLETED BY THE CONTRACTOR, Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE		RECEIVED	
TECHNICAL OFFICE		25 AUG 2008 0753	
SITE MANAGER		15 2012	
		PROJECT: SP43	
LEGEND	QTY: Quantity	N/A: Not Applicable	REF: Reference



# INSPECTION REPORT

DATE: 27 FEB 2008

PROJECT TYPE: GOODS INWARDS INSPECTION		LOCATION: EPD/SP12/Phase 1	
INSPECTION NOTICE NO.: HWP-NASH/0102		SIGNATURE	
CONTRACTOR'S INSPECTOR:		CONTRACTOR:	SUBCONTRACTOR:
CONTRACTOR'S INSPECTOR:			
DESCRIPTION: Insprod 100			
SUPPLIER: FOSADOC			
DRAWING NO.:			
ACCEPTANCE CRITERIA: As per Qty To Specification			
QTY ITEMS RECEIVED:	NA	CONTRACT NO. (LOCAL) / 00	
QTY ITEMS INSPECTED:	NA	SUPPLIER REFERENCE:	
QTY ITEMS ACCEPTED:	NA	CERTIFICATION: / no/na/	
QTY ITEMS REJECTED:	NA		
COMMENTS:			
TO BE COMPLETED BY THE CONTRACTOR O.C.W. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION:			
ORIGINAL: PPL			
TECHNICAL OFFICE			
SITTING MANAGER			
LEGEND	QTY: Quantity	NA: Not Applicable	REF: Reference

**RECEIVED**

27 FEB 2008

NO: 0124  
PPL KANGAR - PROJECT SP12



# INSPECTION REPORT

DATE: 27 FEB 2008

PROJECT TYPE: GOODS INWARDS INSPECTION		LOCATION: EPD/SP12/Phase 1	
INSPECTION NOTICE NO.: HMM-NASH/0102		SIGNATURE	
CONTRACTOR'S INSPECTOR:		CONTRACTOR:	SUBCONTRACTOR:
CONTRACTOR'S INSPECTOR:			
DESCRIPTION: Insprod 100			
SUPPLIER: KOSARDC			
DRAWING NO.:			
ACCEPTANCE CRITERIA: As per Qty To Specification			
QTY ITEMS RECEIVED:	NA	CONTRACT NO. (LOCAL) / 30	
QTY ITEMS INSPECTED:	NA	SUPPLIER REFERENCE:	
QTY ITEMS ACCEPTED:	NA	CERTIFICATION: / no/na/	
QTY ITEMS REJECTED:	NA		
COMMENTS:			
TO BE COMPLETED BY THE CONTRACTOR O.C.W. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION:			
ORIGINAL: PPL			
TECHNICAL OFFICE			
SITTING MANAGER			
LEGEND	QTY: Quantity	NA: Not Applicable	REF: Reference

**RECEIVED**  
 27 FEB 2008  
 NO: 0124  
 PPL KANGAR - PROJECT SP12



# INSPECTION REPORT

Date: 25-Aug-06

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (SD) Navros Co. (storage)	
INSPECTION NOTICE NO.: RMA-CV-011 R1		INSPECTOR'S SIGNATURE	
COMPANY'S INSPECTOR:		COMPANY:	CONTRACTOR:
CONTRACTOR'S INSPECTOR: E. Nazer			
DESCRIPTION: <b>Loctite SBQ For Anchor Bolt Repairing</b> (Mix and place polyester resin anchoring grouts)			
SUPPLIER: <b>FOSROC Constructive Solutions</b>			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:		CONTRACT NO.: 861 CCA-01793	
QTY ITEMS INSPECTED: N/A		SUPPLIER'S REF: FOSROC Constructive Solutions	
QTY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
QTY ITEMS REJECTED: N/A			
COMMENT: <i>The sample should be submitted.</i> <i>J. H. H.</i> <i>25 Aug 06</i>			
TO BE COMPLETED BY THE CONTRACTOR (Q.C.M.) BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE			
TECHNICAL OFFICE			
SITE MANAGER			
LEGEND	QTY: Quantity	N/A: Not Applicable	REF: Reference



# INSPECTION REPORT

Date: 20-4-08

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Legeur Camp (BD)Navrod Co (storage)	
INSPECTION NOTICE NO: RMA-DV-012 R1		SIGNATURE	
COMPANY'S INSPECTOR:		COMPANY:	
CONTRACTOR'S INSPECTOR: E. Nassif		CONTRACTOR:	
DESCRIPTION: <b>Concrete CR (Fos)</b> : 02 (General purpose for other demarcation grid)			
SUPPLIER: <b>FOSROC Constructive Solutions</b>			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification			
QTY ITEMS RECEIVED:		CONTRACT NO: 821004-01793	
QTY ITEMS INSPECTED: N/A		SUPPLIER REF: FOSROC Constructive Solutions	
QTY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
QTY ITEMS REJECTED: N/A			
COMMENT: <i>The sample should be submitted</i> <i>for analysis</i>			
TO BE COMPLETED BY THE CONTRACTOR OR IN BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION			
ORIGINAL FILE		RECEIVED	
TECHNICAL OFFICE		20-04-08 07:00	
BY: [Signature]		0012	
LEGEND: QTY QUANTITY		REF: Reference	



# INSPECTION REPORT



Date: 20-Aug-06

INSPECTION TYPE: GOODS INWARDS INSPECTION		LOCATION: Labour Camp (SD)Navrod Co.(storage)	
INSPECTION NOTICE NO.: RMA-CV-016.R1		SIGNATURE	
COMPANY'S INSPECTOR:		COMPANY	CONTRACTOR
CONTRACTOR'S INSPECTOR: E.Nazer		20-AUG-06	
DESCRIPTION: Silica fume admixture			
SUPPLIER: FOSPOC Constructive Solutions (Went. sanati)			
DRAWING NO(S): N/A			
ACCEPTANCE CRITERIA: According To Specification SP12-2Y-CV-SF-993-010			
Q'TY ITEMS RECEIVED:		CONTRACT NO: 861CCA-01783	
Q'TY ITEMS INSPECTED: N/A		SUPPLIERS REF: FOSPOC Constructive Solutions	
Q'TY ITEMS ACCEPTED: N/A		CERTIFICATION: Attachment	
Q'TY ITEMS REJECTED: N/A			
COMMENT: <i>The sample should be submitted for testing as per spec</i>			
TO BE COMPLETED BY THE CONTRACTOR, Q.C.M. BELOW THIS LINE			
RECOMMENDATIONS:			
DISTRIBUTION		RECEIVED	
ORIGINAL FILE		20 AUG 2006 09:50	
TECHNICAL OFFICE		09:10	
SITE MANAGER		FOSPOC CONSTRUCTIVE SOLUTIONS	
LEGEND	QTY : Quantity	N/A : Not Applicable	REF : Reference



# INSPECTION REPORT

Date: 22-4-2025

INSPECTION TYPE: GOODS INWARDS INSPECTION	LOCATION: LEBUR DAM, SOINAVIA CO. (Storage)
--	---

INSPECTION NOTICE NO.: PWA-0001-24-0	SIGNATURE
--------------------------------------	-----------

COMPANY'S INSPECTOR:	CONTRACT NO.	CONTRACTOR
----------------------	--------------	------------

CONTRACTOR'S INSPECTOR: E. NSEDI		
----------------------------------	--	--

DESCRIPTION: **Complet. SPACING** - Dispersing admixture.

SUPPLIER: **ROBROD Constructive Sol.**

DRAWING NO(S): N/A

ACCEPTANCE CRITERIA: According To Specification

QTY ITEMS RECEIVED:	CONTRACT NO: SBY004-01785
---------------------	---------------------------

QTY ITEMS INSPECTED: N/A	SUPPLIER'S REF: ROBROD Constructive Solutions
--------------------------	---

QTY ITEMS ACCEPTED: N/A	CERTIFICATION: Attachment
-------------------------	---------------------------

QTY ITEMS REJECTED: N/A	
-------------------------	--

COMMENT:  
*It is approved, that the material is with order form and this material also the submittal.*  
*E. NSEDI*  
*Inspector*

TO BE COMPLETED BY THE CONTRACTOR QTY BELOW THIS LINE

RECOMMENDATIONS:

DISTRIBUTION  
 ORIGINAL FILE  
 TECHNICAL OFFICE  
 SITE MANAGER

LEGEND	QTY: Quantity	N/A: Not Applicable	REF: Refer to
--------	---------------	---------------------	---------------